

# PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2011010305501941

Valid from: Apr.16,2021

Valid until: Apr.16,2031

<b>NAME AND REGISTERED ADDRESS OF THE APPLICANT</b>	SOCOMECS.A 1, Rue De Westhouse 67230 Benfeld Cedex France
<b>NAME AND REGISTERED ADDRESS OF THE MANUFACTURER</b>	SOCOMECS.A 1, Rue De Westhouse 67230 Benfeld Cedex France
<b>NAME AND LOCATION OF THE FACTORY</b>	SOCIETE TIMELEC SARL ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia
<b>PRODUCT NAME, MODEL AND SPECIFICATION</b>	Automatic Transfer Switching Equipment ATyS□□ ; See the appendix
<b>THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS</b>	GB/T 14048.11-2016
<b>TYPE OF CERTIFICATION SCHEMES</b>	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.  
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNED BY:

PRESIDENT:

CHINA QUALITY CERTIFICATION CENTRE



# 产品认证证书

## II型自愿认证

附 录

证书编号: CQC2011010305501941

第 1 页 共 2 页

纸 号: 31492

ATyS□□;

Ui: 800V(主回路), 300V(控制回路); Uimp: 6kV(主回路), ATyS dM: 4kV, ATyS pM、ATyS gM、ATyS tM、ATyS cM: 2.5kV (控制回路);

Ith: 160A; Ue: 240VAC(ATyS dM 2P, ATyS gM 2P), 138/240VAC(ATyS dM 4P, ATyS gM 4P, ATyS pM 4P), 240/415VAC(ATyS dM 4P, ATyS gM 4P, ATyS tM 4P, ATyS cM 4P, ATyS pM 4P);

ATyS dM、ATyS pM、ATyS cM: Ie: AC-32B, AC-33iB: 40, 63, 80, 100, 125, 160A; AC-33B: 40, 63, 80, 100, 125A;

AC-32A: 40, 63, 80, 100A;

ATyS gM: Ie: 2P: AC-32B, AC-33iB: 40, 63, 80, 100, 125, 160A;

AC-33B: 40, 63, 80, 100, 125A;

AC-32A: 40, 63, 80, 100A;

Ie: 4P: AC-32B, AC-33iB: 20, 32, 40, 63, 80, 100, 125, 160A;

AC-33B: 20, 32, 40, 63, 80, 100, 125A;

AC-32A: 20, 32, 40, 63, 80, 100A;

ATyS tM: Ie: AC-32B, AC-33iB: 20, 32, 40, 63, 80, 100, 125, 160A;

AC-33B: 20, 32, 40, 63, 80, 100, 125A;

AC-32A: 20, 32, 40, 63, 80, 100A;

使用类别: AC-32A、AC-32B、AC-33iB、AC-33B;

Iq: 160A: 40kA; 125A、100A、80A、63A、40A、32A、20A: 50kA;

电器级别: PC 级; 转换方式: ATSE, RTSE;

极数: 2P(ATyS dM, ATyS gM), 4P(ATyS dM, ATyS gM, ATyS tM, ATyS cM, ATyS pM);

注: 此附录与证书同时使用时有效。



### 中国质量认证中心

# 产品认证证书

## II型自愿认证

附 录

证书编号: CQC2011010305501941

第 2 页 共 2 页

纸 号: 31492

型号解释:

ATyS    □    □  
①        ②        ③

- ① 企业产品系列名称: 自动(遥控)转换开关
- ② 控制类型: dM 是 RTSE, gM, tM, cM 和 pM 是 ATSE, 控制器 gM 和 tM 无 LCD, cM 和 pM 有 LCD.
- ③ 电流规格: 20A, 32A, 40A, 63A, 80A, 100A, 125A, 160A.

注: 此附录与证书同时使用时有效。



### 中国质量认证中心