



中国国家强制性产品认证证书

证书编号: 2024010302646930

认证委托人名称及地址

法国溯高美电气公司

1, Rue De Westhouse 67230 Benfeld Cedex France

生产者名称及地址

法国溯高美电气公司

1, RUE de Westhouse 67230 BENFELD FRANCE

生产企业名称及地址

SOCIETE TIMELEC SARL

ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN

GOUVERNORAT DE BEN AROUS, Tunisia

产品名称和系列、型号、规格

负荷隔离开关

SIRCO PV 100A, SIRCO PV 125A, SIRCO PV 160A, SIRCO PV 200A, SIRCO PV 250A, SIRCO PV 315A, SIRCO PV 400A, SIRCO PV 500A; 额定冲击耐受电压(Uimp):12kV; 额定绝缘电压(Ui): 1000V; 约定发热电流(Ith): 100A, 125A, 160A, 200A, 250A, 315A, 400A, 500A; 额定工作电压(Ue): DC750V(3P外形), DC1000V(4P外形); 额定工作电流(Ie): 100A, 125A, 160A, 200A, 250A, 315A, 400A, 500A; 额定短时耐受电流(Icw):8kA/1s; 额定短路接通能力(Icm):13.6kA; 使用类别: DC-21B; 极数: 3P外形, 4P外形; 直流接线图见附页

产品标准和技术要求

GB/T 14048.3-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》(CNCA-C03-02:2024)的要求, 特发此证。

发证日期: 2024年06月25日 有效期至: 2029年06月24日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验, 也可在认监委网站(www.cnca.gov.cn)查询。



签发:

谢肇煦



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010302646930

证书附页：第 1 页 共 1 页

直流接线图：



本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010302646930

NAME AND ADDRESS OF THE APPLICANT
SOCOMEC S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND ADDRESS OF THE MANUFACTURER
SOCOMEC S.A.S
1,RUE de Westhouse 67230 BENFELD FRANCE

NAME AND LOCATION OF THE FACTORY
SOCIETE TMELEC SARL
ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN
GOUVERNORAT DE BEN AROUS, Tunisia

PRODUCT NAME, MODEL AND SPECIFICATION
Load Switch-disconnector

SIRCO PV 100A, SIRCO PV 125A, SIRCO PV 160A, SIRCO PV 200A, SIRCO PV 250A, SIRCO PV 315A, SIRCO PV 400A, SIRCO PV 500A ;U imp:12kV ;U i: 1000V ;Ith: 100A, 125A, 160A ,200A, 250A, 315A, 400A, 500A ;U e: DC 750V (3P style), DC 1000V (4P style);Ie: 100A, 125A, 160A ,200A, 250A, 315A, 400A, 500A ;Icw :8kA /1s;Icm :13.6kA ;Utilization category: DC-21B ;Poles: 3P style, 4P style; See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS
GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C03-02:2024).

Valid from : Jun.25,2024 Valid until: Jun.24,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.






CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION


本翻译文件不具有法律效力，不得单独使用
This translated document does not have legal validity and cannot be used in isolation

CERTIFICATE NO. : 2024010302646930


Appendix: Page 1 of 1



4 极 (1000VDC): 两极串联为正负极



3 极 (750VDC): 两极串联为正极



This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.